




# KNX K8

## Actuator for heating and cooling

### Technical specifications and installation instructions

Item number 70321



**Elsner Elektronik GmbH** Control and Automation Engineering

Sohlengrund 16  
75395 Ostelsheim  
Germany

Phone +49 (0) 70 33 / 30 945-0 info@elsner-elektronik.de  
Fax +49 (0) 70 33 / 30 945-20 www.elsner-elektronik.de

Technical support: +49 (0) 70 33 / 30 945-250

# 1. Description

The **KNX K8 actuator** offers eight internal temperature regulators and eight output channels for controlling heating or cooling systems. The temperature regulators can control both the outputs on the **KNX K8** and other climate control system on the KNX-Bus.

In automatic mode, the temperature regulators are set at nominal temperatures for different modes. This way, it is easy to switch between the modes, comfort, standby, eco and building protection. The switch is made via an object e. g. via a manual switch, time switch or sensor switch outputs in the KNX-System.

The buttons on the device allow for direct manual switching of the connected systems. LEDs show whether the output channel was manually operated or is running in an automatic mode.

## Functions:

- **8 internal, independent temperature regulators** with automatic controls for the **heating and cooling controls** (one or two step heating and cooling)
- **8 output channels** (230 V AC, 8 Watt per output) with pulse width modulation control (PWM) for actuators
- Keypad field **8 buttons** and status LEDs

Configuration is made using the KNX software ETS. The **product file** can be downloaded from the Elsner Elektronik homepage on **www.elsner-elektronik.de** in the "Service" menu.

## 1.1. Technical data

Housing	Plastic
Colour	White
Mounting	Series installation on mounting rail
Protection category	IP 20
Dimensions	approx. 107 x 88 x 60 (W x H x D, mm), 6 modules
Weight	approx. 270 g
Ambient temperature	Operation -20...+70°C, storage -55...+90°C
Ambient humidity	max. 95% RH, avoid condensation
Operating voltage	230V AC, 50 Hz
Power consumption	max. 2 W
Power	on bus: 10 mA
Outputs	8 x 230 V (OUT/N), not short-circuit-proof. When connecting one consumer load per separate channel (1 to 8): Max. load for continuous operation: 8 W per channel Max. switch-on current: 1.1 A per channel Observe the specifications in the data sheet of the consumer load.
Data output	KNX +/- bus connector terminal

BCU type	unit's own microcontroller
PEI type	0
Group addresses	max. 254
Assignments	max. 254
Communication objects	249

The product conforms with the provisions of EU directives.

## 2. Installation and start-up

### 2.1. Installation notes



Installation, testing, operational start-up and troubleshooting should only be performed by an electrician.



#### **DANGER!**

#### **Risk to life from live voltage (mains voltage)!**

There are unprotected live components within the device.

- VDE regulations and national regulations are to be followed.
- Ensure that all lines to be assembled are free of voltage and take precautions against accidental switching on.
- Do not use the device if it is damaged.
- Take the device or system out of service and secure it against unintentional use, if it can be assumed, that risk-free operation is no longer guaranteed.


The device is only to be used for its intended purpose. Any improper modification or failure to follow the operating instructions voids any and all warranty and guarantee claims.

After unpacking the device, check it immediately for possible mechanical damage. If it has been damaged in transport, inform the supplier immediately.

The device may only be used as a fixed-site installation; that means only when assembled and after conclusion of all installation and operational start-up tasks and only in the surroundings designated for it.

Elsner Elektronik is not liable for any changes in norms and standards which may occur after publication of these operating instructions.

## 2.2. Device connection and design



## 2.3. Notes on mounting and commissioning

Device must not be exposed to water (rain). This could result in the electronics being damaged. A relative air humidity of 95% must not be exceeded. Avoid condensation.

After the operating voltage has been applied, the device will enter an initialisation phase lasting a few seconds. During this phase no information can be received or sent via the bus.

### 2.3.1. Buttons and LEDs for the output channels

The buttons on the devices can be deactivated in the ETS (active when delivered).

### Buttons

brief button press (<0,5 s)	LED shows current status (see ETS parameter: Channel LED)
button press >0,5 s	<i>in Automatic mode:</i> Switching to Manual mode <i>in Manal mode:</i> Switching from manually ON to manually OFF and reverse
long button press (>3 s)	Switching to Automatic mode (when activated in ETS)

### LEDs

Behaviour of the LEDs for the output channels  
in Automatic mode:

Off	Actuating variable = 0%
On	Actuating variable > 0%

in Manual mode:

Flashes slowly	Manually OFF
Flashes fast	Manually ON